


3C X 40/0.076 PVC FLEX CABLE



Technical info


PVC sheathed flexible cord(40YARD)		Type:3C×40(TA)			
standa	standard:GB/T5023-2008		Length:40YARD		
	Item	requirement:	Result	Conclusion	
Candustan	The number	3×40	3×40	Pass	
Conductor	Diameter(mm)	≤0.21	0.125	Pass	
la colation	AVG(mm)	≥0.6	0.8	Pass	
Insulation	Mix(mm)	≥0.44	0.67	Pass	
Sheath	AVG(mm)	≥0.8	1.0	Pass	
Sneath	Mix(mm)	≥0.58	0.82	Pass	
Outer diameter(mm)		7.3	7.3	Pass	
Logo		CRM			
Test Conclusion			items meet the requirement ird GB/T5023-2008 in Chin		

Stock code

No.	Description
CAF340.	CRM 3C X 40/0.076 PVC FLEX CABLE
CAF340.H	CRM 3C X 40/0.076 PVC FLEX CABLE (W)
CAF340.D	CRM 3C X 40/0.076 PVC FLEX CABLE(BK)



3C X 70/0.076 PVC FLEX CABLE



Technical info


PVC sheathed flexible cord(40YARD)		Type:3C×70(TA)			
stanc	standard:GB/T5023-2008		Length:40YARD		
	ltem		Result	Conclusion	
Conductor	The number	3×70	3×70	Pass	
Conductor	Diameter(mm)	≤0.21	0.125	Pass	
Incolation	AVG(mm)	≥0.6	0.8	Pass	
Insulation	Mix(mm)	≥0.44	0.65	Pass	
Chaath	AVG(mm)	≥0.8	1.1	Pass	
Sheath	Mix(mm)	≥0.58	0.86	Pass	
Ou	Outer diameter(mm)		8.3	Pass	
	Logo		CRM		
-	Test Conclusion		The inspected items meet the requirements of the standard GB/T5023-2008 in China.		

Stock code

No.	Description
CAF370.	CRM 3C X 70/0.076 PVC FLEX CABLE
CAF370.H	CRM 3C X 70/0.076 PVC FLEX CABLE (W)
CAF370.D	CRM 3C X 70/0.076 PVC FLEX CABLE(BK)



3C X 110/0.076 PVC FLEX CABLE



Technical info


PVC sheathed	PVC sheathed flexible cord(40YARD)		Type:3C×110(TA)		
standar	standard:GB/T5023-2008		Length:40YARD		
	Item	requirement:	Result	Conclusion	
Canaduratan	The number	3×110	3×110	Pass	
Conductor	Diameter(mm)	≤0.26	0.125	Pass	
la sulation	AVG(mm)	≥0.7	1.1	Pass	
Insulation	Mix(mm)	≥0.53	0.97	Pass	
Sheath	AVG(mm)	≥0.9	1.3	Pass	
Sneath	Mix(mm)	≥0.67	1.16	Pass	
Oute	Outer diameter(mm)		10.9	Pass	
	Logo		CRM		
Test Conclusion			items meet the requireme ard GB/T5023-2008 in China		

Stock code

No.	Description
CAF3110.	CRM 3C X 110/0.076 PVC FLEX CABLE



4C X 40/0.076 PVC FLEX CABLE



Technical info


Name:PVC sheathed flexible cord(40YARD)		Type:4C×40(TA)			
standard: GB/T5023-2008		Length:40YARD			
ltem		requirement:	Result	Conclusion	
Conductor	The number	4×40	4×40	Pass	
Conductor	Diameter(mm)	≤0.21	0.125	Pass	
Insulation	AVG(mm)	≥0.6	0.8	Pass	
msulation	Mix(mm)	≥0.44	0.65	Pass	
Sheath	AVG(mm)	≥0.8	1.2	Pass	
Sneath	Mix(mm)	≥0.58	1.03	Pass	
Outer diameter(mm)		8.2	8.5	Pass	
Logo		CRM			
Test Conclusion			d items meet the requirement dard GB/T5023-2008 in China.	s of the	

Stock code

No.	Description
CAF440.GL-	CRM 4C X 40/0.076 PVC FLEX CABLE



4C X 70/0.076 PVC FLEX CABLE



Technical info


PVC sheathed flexible cord(40YARD)		Type:4C×70(TA)			
standa	standard:GB/T5023-2008		Length:40YARD		
	ltem		Result	Conclusion	
Canductor	The number	4×70	4×70	Pass	
Conductor	Diameter(mm)	≤0.21	0.125	Pass	
la sulation	AVG(mm)	≥0.6	0.8	Pass	
Insulation	Mix(mm)	≥0.44	0.65	Pass	
Sheath	AVG(mm)	≥0.9	1.0	Pass	
Sneath	Mix(mm)	≥0.67	0.88	Pass	
Oute	r diameter(mm)	8.7	8.9	Pass	
	Logo		CRM		
Test Conclusion			items meet the requireme ard GB/T5023-2008 in China		

Stock code

No.	Description
CAF370.	CRM 3C X 70/0.076 PVC FLEX CABLE
CAF370.H	CRM 3C X 70/0.076 PVC FLEX CABLE (W)
CAF370.D	CRM 3C X 70/0.076 PVC FLEX CABLE(BK)



4C X 110/0.076 PVC FLEX CABLE



Technical info

PVC sheathed flexible cord(40YARD)		Type:4C×110(TA)			
standard	standard:GB/T5023-2008		Length:40YARD		
	Item	requirement:	Result	Conclusion	
Canadanatan	The number	4×110	4×110	Pass	
Conductor	Diameter(mm)	≤0.26	0.125	Pass	
I I	AVG(mm)	≥0.7	1.2	Pass	
Insulation	Mix(mm)	≥0.53	1.05	Pass	
Cl. II	AVG(mm)	≥1.0	1.4	Pass	
Sheath	Mix(mm)	≥0.75	1.22	Pass	
Outer diameter(mm)		12.0	12.3	Pass	
Logo			CRM		
Test Conclusion			items meet the requirement ard GB/T5023-2008 in China		

Stock code

No.	Description
CAF4110.GL-	CRM 4C X 110/0.076 PVC FLEX CABLE